



filled in by the organiser

Notification Form for Generator

The organiser must apply in advance to the Fire Department for all generators to be brought to the Service Park. If you use your own generator, please make sure to submit **the completed notification form for generator form, the layout drawing of the service with clearly indicate the position of the generator, service park facilities order form (if necessary) and specifications for generators not made in Japan** to the organiser's document platform **by Friday 10 October 2025**.

Links; [FIA championship registered teams](#) / [Non-Priority drivers](#)

*The organiser must submit specifications and drawings of the generator (e.g., instruction manual file, catalog excerpt, etc.) to the fire department in advance. They will check in advance whether an oil guard (oil pan) is installed or not. If the information is available on a website, please fill in the URL in the field below.

Note:

- One fire extinguisher must be placed next to each generator (one extinguisher per generator) in accordance with the instructions from the fire department. Fire extinguishers should be "Powder ABC extinguishers" or "fire extinguishers for electrical fires, oil fires and ordinary fires".
- Provide an open space of at least 1 m around the generator. It is prohibited to cover up the generator (Including the upper part).
- A sheet must be placed under the generator to prevent fuel or oil from spilling onto the ground. If a sheet is not in place at the time of the inspection by the fire department and the organizer is required to take action, the cost will be borne by the participant.
- For the storage of gasoline, it may be necessary to submit a temporary storage and handling permit application form for hazardous materials, which will incur additional costs. Please contact the organizer entry@rally-japan.jp
- Please apply to the organiser for diesel fuel for generators. We will refuel directly as needed, so please note that you do not store diesel fuel.
- During the rally, the Toyota City Fire Department will conduct on-site inspections.

Competitor (Team)	
Crew(s)	
Name of contact person	
Mobile number during the event	
e-mail address	

Generator Specifications

Name of manufacturer	
Model Name	
Quantity of generators of the same type	
Fuel type	<input type="checkbox"/> Diesel <input type="checkbox"/> Gasoline
Fuel tank capacity	liters
Fuel spill prevention	<input type="checkbox"/> With <input type="checkbox"/> Without
URL of the website that the generator specifications and drawings can be viewed	

Please attach the photos of generator, if possible.

<Fire extinguisher>

The fire extinguisher must be labeled all "A" "B" "C" according to Japanese standards. ABC is a national standard (Japan) and indicates the type of fire that can be handled.



A: Normal fires



B: Oil fires



C: Electrical fires

- As mentioned earlier, please mark the placement of the generator should be clearly shown on the layout drawing.
- If necessary, please apply to the organizer to rent a fire extinguisher and oil pan.

Thank you for adhering to the rules. Your understanding and cooperation are greatly appreciated.