



Notification Form for Generator

If you use a generator in the service park, you must apply in advance to the fire department via the organizer. Please make sure to submit the following items to the organiser's document platform **by Tuesday 28 April**.

Link; [Registration and Submission Forms](#)

<Items to be submitted>

1. Notification Form for Generator (this form)
2. Team Service Layout Drawing clearly showing the generator installation position at your site.

The organiser must submit specifications and drawings of the generator (e.g., instruction manual file, catalog excerpt, etc.) to the fire department in advance. They will check in advance whether an oil guard (oil pan) is installed or not. If the information is available on a website, please fill in the URL in the field below.

If appropriate are not taken regarding oil or fuel, the fire department may issue an order prohibiting the use of the generator.

<Notes>

- One Japanese-made fire extinguisher must be located next to each generator in accordance with the instructions of the fire department (one extinguisher per generator).
- Fire extinguishers must be 'ABC powder extinguishers' for electrical fires, oil fires and ordinary fires according to Japanese standards and prepare Japanese-made products. Fire departments will not approve any fire extinguishers other than those manufactured in Japan.
- Provide an open space of at least 1 m around the generator.
- It is prohibited to cover up the generator (Including the upper part).
- A sheet must be placed under the generator to prevent fuel or oil from spilling onto the ground for FIA Environmental Accreditation. If a sheet is not in place at the time of the inspection by the fire department and the organizer is required to take action, the cost will be borne by the participant.
- Please apply to the organiser for diesel fuel for generators, the staff from the petrol station will refuel the generator with diesel directly as needed. Please note that you cannot store diesel fuel.
- For the storage of gasoline, it may be necessary to submit a temporary storage and handling permit application form for hazardous materials, which will incur additional costs. Please contact the organiser.

entry@rally-japan.jp

- During the rally, the Toyota City Fire Department will conduct on-site inspections.

Competitor (Team)	
Crew(s)	
Name of contact person	
Mobile number during the event	
e-mail address	

Generator Specifications

Name of manufacturer	
Model Name	
Quantity of generators of the same type	
Fuel type	<input type="checkbox"/> Diesel <input type="checkbox"/> Gasoline
Fuel tank capacity	liters
Fuel spill prevention	<input type="checkbox"/> With <input type="checkbox"/> Without
URL of the website that the generator specifications and drawings can be viewed	

Please attach the photos of generator, if possible.

< Japanese-made fire extinguisher >

The fire extinguisher must be labeled all "A" "B" "C" according to Japanese standards. ABC is a national standard (Japan) and indicates the type of fire that can be handled.



A: Normal fires



B: Oil fires



C: Electrical fires

- As mentioned earlier, please mark the placement of the generator should be clearly shown on the layout drawing.
- If necessary, please apply to the organizer to rent a fire extinguisher and oil pan.

Thank you for adhering to the rules. Your understanding and cooperation are greatly appreciated.